

Analysis of Water Sample

Client Glen Innes Severn Council,
 Glen Innes Sewage Treatment Works Report 28th March 2022
 Water Sample collected 22nd March 2022 Analysis complete 28th March 2022
 Sample collected by Emily Leach
 Samples received chilled - 22nd March 2022

RESULTS - Glen Innes 22nd March 2022

mg L⁻¹ = part per million)

Parameter			Licence Limit (90th %ile)	Units	Method
Ammonia NH ₃ -N	0.98		2	mg L ⁻¹	APHA 4500-NH ₃ C
Biochemical Oxygen Demand (5 days)	13.5		10	mg L ⁻¹	APHA 5210 B
Elect. conductivity (EC)	526			uS cm ⁻¹	APHA 2510 B
Faecal Coliforms	<1		200	cfu/ 100 mL	Membrane Filter APHA 9222 D
NO ₂ and NO ₃ -N	1.0			mg L ⁻¹	APHA 4110 B
Oil & Grease	<2		2	mg L ⁻¹	USEPA 1664
pH	7.32		6.5-8.5	pH units	APHA 4500-H ⁺ B
Soluble Reactive P (SRP)	0.14			mg L ⁻¹	APHA 4110 B
Total phosphorus	0.17		0.3	mg L ⁻¹	APHA 4500 P E
TKN - N	2.4			mg L ⁻¹	APHA 4500-N _{org} C
TN	3.4		10	mg L ⁻¹	TKN + NO ₂ +NO ₃
Total suspended solids TSS	13		15	mg L ⁻¹	APHA 2540 D

0<0.x = measured but reading below detection level

Reference: APHA (2005) *Standard Methods for the Examination of Water and Wastewater*. 21st Edition 2005.

Comments. Please note the Lower detection limit under USEPA 1664 is 2 mg/L for Oil & Grease

Glen Innes Weir - elemental analysis										
Glen Innes - 22M	Na	K	Mg	Ca	SAR	Hardness	Sulphur	TDS	Alkalinity	Chloride
Glen Innes - 22MAR22	mg/L	mg/L	mg/L	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L
	51.8	12.1	19.9	27.1	1.8	150	16.5	352	169	65

