

## Analysis of Water Sample

**Client** Glen Innes Severn Council,

Glen Innes Sewage Treatment Works *Report 28<sup>th</sup> February 2023*

**Water Sample collected** 21<sup>st</sup> February 2023 Analysis complete 28<sup>th</sup> February 2023

**Sample collected by** Pramod Lamsal **Samples received chilled** 21<sup>st</sup> February 2023

## RESULTS - GLEN INNES - 21<sup>st</sup> February 2023

mg L<sup>-1</sup> = part per million)

Parameter			EPA Limit 90 <sup>th</sup> %ile	Units	Method
Ammonia NH <sub>3</sub> -N	0.42		2.0	mg L <sup>-1</sup>	APHA 4500-NH <sub>3</sub> C
Biochemical Oxygen Demand (5 days)	8.4		10	mg L <sup>-1</sup>	APHA 5210 B
Elect. conductivity (EC)	733			uS cm <sup>-1</sup>	APHA 2510 B
Faecal Coliforms	12		200	cfu/ 100 mL	Membrane Filter APHA 9222 D
NO <sub>2</sub> and NO <sub>3</sub> -N	2.4			mg L <sup>-1</sup>	APHA 4110 B
Oil & Grease	<2		2	mg L <sup>-1</sup>	USEPA 1664
pH	7.68		6.8-8.5	pH units	APHA 4500-H <sup>+</sup> B
Soluble Reactive P (SRP)	0.18			mg L <sup>-1</sup>	APHA 4110 B
Total phosphorus	0.21		0.3	mg L <sup>-1</sup>	APHA 4500 P E
TKN - N	2.8			mg L <sup>-1</sup>	APHA 4500-N <sub>org</sub> C
TN	5.2		10	mg L <sup>-1</sup>	TKN + NO <sub>2</sub> +NO <sub>3</sub>
Total suspended solids TSS	8		15	mg L <sup>-1</sup>	APHA 2540 D

0<0.x = measured but reading below detection level

**Reference:** APHA (2005) *Standard Methods for the Examination of Water and Wastewater*. 21st Edition 2005.

**Comments.** Please note the Lower detection limit under USEPA 1664 is 2 mg/L for Oil & Grease

Glen Innes Weir - elemental analysis										
Glen Innes- 21FE	Na	K	Mg	Ca	SAR	Hardness	Sulphur	TDS	Alkalinity	Chloride
	mg/L	mg/L	mg/L	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L
Glen Innes- 21FEB23	72.3	18.6	26.8	34.0	2.3	195	22.0	491	164	119

