

Analysis of Water Sample

Client Glen Innes Severn Council,
 Glen Innes Sewage Treatment Works *Report 28th May 2023*
Water Sample collected 23rd May 2023 *Analysis complete 28th May 2023*
Sample collected by Emily Leach *Samples received chilled 23rd May 2023*

RESULTS - GLEN INNES - 23rd May 2023

mg L⁻¹ = part per million)

Parameter			EPA Limit 90 th %ile	Units	Method
Ammonia NH ₃ -N	0.82		2.0	mg L ⁻¹	APHA 4500-NH ₃ C
Biochemical Oxygen Demand (5 days)	6.2		10	mg L ⁻¹	APHA 5210 B
Elect. conductivity (EC)	672			uS cm ⁻¹	APHA 2510 B
Faecal Coliforms	2		200	cfu/ 100 mL	Membrane Filter APHA 9222 D
NO ₂ and NO ₃ -N	1.49			mg L ⁻¹	APHA 4110 B
Oil & Grease	<2		2	mg L ⁻¹	USEPA 1664
pH	7.31		6.8-8.5	pH units	APHA 4500-H ⁺ B
Soluble Reactive P (SRP)	0.02			mg L ⁻¹	APHA 4110 B
Total phosphorus	0.36	Elevated	0.3	mg L ⁻¹	APHA 4500 P E
TKN - N	2.9			mg L ⁻¹	APHA 4500-N _{org} C
TN	4.4		10	mg L ⁻¹	TKN + NO ₂ +NO ₃
Total suspended solids TSS	17.5	elevated	15	mg L ⁻¹	APHA 2540 D

0<0.x = measured but reading below detection level

Reference: APHA (2005) *Standard Methods for the Examination of Water and Wastewater*. 21st Edition 2005.

Comments. Please note the Lower detection limit under USEPA 1664 is 2 mg/L for Oil & Grease

Glen Innes STP - elemental analysis										
MAY 2023	Na	K	Mg	Ca	SAR	Hardness	Sulphur	TDS	Alkalinity	Chloride
Glen Innes- 23MAY23	mg/L	mg/L	mg/L	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L
	62.6	14.1	26.4	30.4	2.0	185	24.0	450	107	142

