

## Analysis of Water Sample

**Client** Glen Innes Severn Council,

Glen Innes Sewage Treatment Works *Report* 6<sup>th</sup> February 2022

**Water Sample collected** 1<sup>st</sup> February 2022 Analysis complete 6<sup>th</sup> February 2022

**Sample collected by** Nicole Wilson **Samples received chilled** 1<sup>st</sup> February 2022

## RESULTS - Glen Innes 1<sup>st</sup> FEBRUARY 2022

mg L<sup>-1</sup> = part per million)

Parameter		Licence Limit (90th%ile)	Units	Method
Ammonia NH <sub>3</sub> -N	1.10	2	mg L <sup>-1</sup>	APHA 4500-NH <sub>3</sub> C
Biochemical Oxygen Demand (5 days)	5.5	10	mg L <sup>-1</sup>	APHA 5210 B
Elect. conductivity (EC)	599		uS cm <sup>-1</sup>	APHA 2510 B
Faecal Coliforms	4	200	cfu/ 100 mL	Membrane Filter APHA 9222 D
NO <sub>2</sub> and NO <sub>3</sub> -N	0.63		mg L <sup>-1</sup>	APHA 4110 B
Oil & Grease	<2	2	mg L <sup>-1</sup>	USEPA 1664
pH	7.21	6.5-8.5	pH units	APHA 4500-H <sup>+</sup> B
Soluble Reactive P (SRP)	<0.01		mg L <sup>-1</sup>	APHA 4110 B
Total phosphorus	<b>0.34</b>	0.3	mg L <sup>-1</sup>	APHA 4500 P E
TKN - N	3.6		mg L <sup>-1</sup>	APHA 4500-N <sub>org</sub> C
TN	4.2	10	mg L <sup>-1</sup>	TKN + NO <sub>2</sub> +NO <sub>3</sub>
Total suspended solids TSS	<b>33</b>	15	mg L <sup>-1</sup>	APHA 2540 D

0<0.x = measured but reading below detection level

**Reference:** APHA (2005) *Standard Methods for the Examination of Water and Wastewater*. 21st Edition 2005.

**Comments.** Please note the Lower detection limit under USEPA 1664 is 2 mg/L for Oil & Grease

Glen Innes Weir - elemental analysis										
February 2022	Na	K	Mg	Ca	SAR	Hardness	Sulphur	TDS	Alkalinity	Chloride
Glen Innes-01FEB22	mg/L	mg/L	mg/L	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L
	65.2	12.0	23.7	28.4	2.2	169	17.8	401	145	78