

Analysis of Water Sample

Client Glen Innes Severn Council,

Glen Innes Sewage Treatment Works *Report* 21st February 2022

Water Sample collected 15th February 2022 **Analysis complete** 21st February 2022

Sample collected by Emily Leach **Samples received chilled** 15th February 2022

RESULTS - Glen Innes 15th FEBRUARY 2022

mg L⁻¹ = part per million)

Parameter		Licence Limit (90th%ile)	Units	Method
Ammonia NH ₃ -N	0.44	2	mg L ⁻¹	APHA 4500-NH ₃ C
Biochemical Oxygen Demand (5 days)	7.2	10	mg L ⁻¹	APHA 5210 B
Elect. conductivity (EC)	654		uS cm ⁻¹	APHA 2510 B
Faecal Coliforms	70	200	cfu/ 100 mL	Membrane Filter APHA 9222 D
NO ₂ and NO ₃ -N	1.42		mg L ⁻¹	APHA 4110 B
Oil & Grease	<2	2	mg L ⁻¹	USEPA 1664
pH	7.72	6.5-8.5	pH units	APHA 4500-H ⁺ B
Soluble Reactive P (SRP)	0.020		mg L ⁻¹	APHA 4110 B
Total phosphorus	0.150	0.3	mg L ⁻¹	APHA 4500 P E
TKN - N	3.3		mg L ⁻¹	APHA 4500-N _{org} C
TN	4.7	10	mg L ⁻¹	TKN + NO ₂ +NO ₃
Total suspended solids TSS	20	15	mg L ⁻¹	APHA 2540 D

0<0.x = measured but reading below detection level

Reference: APHA (2005) *Standard Methods for the Examination of Water and Wastewater*. 21st Edition 2005.

Comments. Please note the Lower detection limit under USEPA 1664 is 2 mg/L for Oil & Grease

Glen Innes Weir - elemental analysis										
February 2022	Na	K	Mg	Ca	SAR	Hardness	Sulphur	TDS	Alkalinity	Chloride
Glen Innes- 15FEB22	mg/L	mg/L	mg/L	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L
	68.8	13.7	22.6	29.2	2.3	166	21.4	438	148	87