

## Analysis of Water Sample

Client Glen Innes Severn Council,

Glen Innes Sewage Treatment Works

Report 10<sup>th</sup> June 2025

Water Sample collected 3<sup>rd</sup> June 2025 Analysis complete 9<sup>th</sup> June 2025

Sample collected by Emily Leach

Samples received chilled 3<sup>rd</sup> June 2025

## RESULTS - GLEN INNES 3<sup>rd</sup> June 2025

mg L<sup>-1</sup> = part per million)

Parameter			EPA Limit 90 <sup>th</sup> %ile	Units	Method
Ammonia NH <sub>3</sub> -N	0.59		2.0	mg L <sup>-1</sup>	APHA 4500-NH <sub>3</sub> C
Biochemical Oxygen Demand (5 days)	3.2		10	mg L <sup>-1</sup>	APHA 5210 B
Elect. conductivity (EC)	595			uS cm <sup>-1</sup>	APHA 2510 B
Faecal Coliforms	<1		200	cfu/ 100 mL	Membrane Filter APHA 9222 D
NO <sub>2</sub> and NO <sub>3</sub> -N	1.85			mg L <sup>-1</sup>	APHA 4110 B
Oil & Grease	<2		2	mg L <sup>-1</sup>	USEPA 1664
pH	7.37		6.8-8.5	pH units	APHA 4500-H <sup>+</sup> B
Soluble Reactive P (SRP)	0.08			mg L <sup>-1</sup>	APHA 4110 B
Total phosphorus	0.14		0.3	mg L <sup>-1</sup>	APHA 4500 P E
TKN - N	3.5			mg L <sup>-1</sup>	APHA 4500-N <sub>org</sub> C
TN	5.4		10	mg L <sup>-1</sup>	TKN + NO <sub>2</sub> +NO <sub>3</sub>
Total suspended solids TSS	3		15	mg L <sup>-1</sup>	APHA 2540 D

0<0.x = measured but reading below detection level

Reference: APHA (2005) *Standard Methods for the Examination of Water and Wastewater*. 21st Edition 2005.

Comments. Please note the Lower detection limit under USEPA 1664 is 2 mg/L for Oil & Grease

Glen Innes Weir - elemental analysis										
JUNE 2025	Na	K	Mg	Ca	SAR	Hardness	Sulphur	TDS	Alkalinity	Chloride
Glen Innes - 03JUN25	mg/L	mg/L	mg/L	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L
	59.1	11.0	21.5	27.6	2.1	157	37.5	399	98	47

