

Analysis of Water Sample

Client Glen Innes Severn Council,

Glen Innes Sewage Treatment Works

Report 20th May 2025

Water Sample collected 13th April 2025 Analysis complete 20th May 2025

Sample collected by Emily Leach

Samples received chilled 30th April 2025

RESULTS - GLEN INNES - 13th May 2025

mg L⁻¹ = part per million)

Parameter			EPA Limit 90 th %ile	Units	Method
Ammonia NH ₃ -N	0.92		2.0	mg L ⁻¹	APHA 4500-NH ₃ C
Biochemical Oxygen Demand (5 days)	9		10	mg L ⁻¹	APHA 5210 B
Elect. conductivity (EC)	755			uS cm ⁻¹	APHA 2510 B
Faecal Coliforms	2		200	cfu/ 100 mL	Membrane Filter APHA 9222 D
NO ₂ and NO ₃ -N	3.49			mg L ⁻¹	APHA 4110 B
Oil & Grease	<2		2	mg L ⁻¹	USEPA 1664
pH	7.29		6.8-8.5	pH units	APHA 4500-H ⁺ B
Soluble Reactive P (SRP)	0.09			mg L ⁻¹	APHA 4110 B
Total phosphorus	0.16		0.3	mg L ⁻¹	APHA 4500 P E
TKN - N	3.0			mg L ⁻¹	APHA 4500-N _{org} C
TN	6.5		10	mg L ⁻¹	TKN + NO ₂ +NO ₃
Total suspended solids TSS	5		15	mg L ⁻¹	APHA 2540 D

0<0.x = measured but reading below detection level

Reference: APHA (2005) *Standard Methods for the Examination of Water and Wastewater*. 21st Edition 2005.

Comments. Please note the Lower detection limit under USEPA 1664 is 2 mg/L for Oil & Grease

Glen Innes STP - elemental analysis										
MAY 2025	Na	K	Mg	Ca	SAR	Hardness	Sulphur	TDS	Alkalinity	Chloride
Glen Innes-13MAY2	mg/L	mg/L	mg/L	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L
	76.8	17.3	24.4	36.2	2.4	191	65.8	506	91	67

