

Phone Office/Lab (02) 6775 1157  
 ABN: 72 212 385 096  
 email: [lanfaxlabs@bigpond.com.au](mailto:lanfaxlabs@bigpond.com.au)  
 Website: [http:// www.lanfaxlabs.net](http://www.lanfaxlabs.net)  
 Lab address: 493 Old Inverell Road  
 Postal: PO Box 4690 Armidale NSW 2350  
 Director: Dr Robert Patterson CPSS,  
 Soil Scientists and Environmental Engineers



Quality Assurance and Quality Control by Approved Methods

## Analysis of Water Sample

Client Glen Innes Severn Council,

Glen Innes Sewage Treatment Works

Report 5<sup>th</sup> May 2025

Water Sample collected 29<sup>th</sup> April 2025 Analysis complete 5<sup>th</sup> May 2025

Sample collected by Emily Leach

Samples received chilled 30<sup>th</sup> April 2025

## RESULTS - GLEN INNES - 29<sup>th</sup> April 2025

mg L<sup>-1</sup> = part per million)

Parameter			EPA Limit 90 <sup>th</sup> %ile	Units	Method
Ammonia NH <sub>3</sub> -N	0.74		2.0	mg L <sup>-1</sup>	APHA 4500-NH <sub>3</sub> C
Biochemical Oxygen Demand (5 days)	3.2		10	mg L <sup>-1</sup>	APHA 5210 B
Elect. conductivity (EC)	647			uS cm <sup>-1</sup>	APHA 2510 B
Faecal Coliforms	5		200	cfu/ 100 mL	Membrane Filter APHA 9222 D
NO <sub>2</sub> and NO <sub>3</sub> -N	3.70			mg L <sup>-1</sup>	APHA 4110 B
Oil & Grease	<2		2	mg L <sup>-1</sup>	USEPA 1664
pH	7.29		6.8-8.5	pH units	APHA 4500-H <sup>+</sup> B
Soluble Reactive P (SRP)	0.080			mg L <sup>-1</sup>	APHA 4110 B
Total phosphorus	0.120		0.3	mg L <sup>-1</sup>	APHA 4500 P E
TKN - N	1.7			mg L <sup>-1</sup>	APHA 4500-N <sub>org</sub> C
TN	5.1		10	mg L <sup>-1</sup>	TKN + NO <sub>2</sub> +NO <sub>3</sub>
Total suspended solids TSS	10		15	mg L <sup>-1</sup>	APHA 2540 D

0<0.x = measured but reading below detection level

Reference: APHA (2005) *Standard Meth230ods for the Examination of Water and Wastewater*. 21st Edition 2005.

Comments. Please note the Lower detection limit under USEPA 1664 is 2 mg/L for Oil & Grease

Glen Innes Weir - elemental analysis										
MAY 2025	Na	K	Mg	Ca	SAR	Hardness	Sulphur	TDS	Alkalinity	Chloride
Glen Innes - 29APR25	mg/L	mg/L	mg/L	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L
	70.0	14.6	23.4	32.2	2.3	177	56.7	433	100	60



Commercial and research laboratory for soil, water and plant analysis.  
 Soil survey and analytical assessments, landscape analysis and plant nutrient relationships,  
 Wastewater and effluent reuse specialists - on-site and decentralised