

COFFS HARBOUR LABORATORY

Environmental Analysis

Page 1 of 1



GLENINNESSEVERN COUNCIL
SAM PRICE
P.O. BOX 61
GLEN INNES NSW 2370

BATCHNUMBER: 25/2486
No. of SAMPLES: 1
DATE COLLECTED: 21/10/25
DATE RECEIVED: 22/10/25
TIME RECEIVED: 11:00
DATE TESTING COMMENCED:
22/10/25

REPORT OF ANALYSIS

SAMPLE REFERENCE	SAMPLE DESCRIPTION
25/2486/1	GLENINNES STP

ANALYSIS	UNITS	25/2486/1				METHOD NO
pH	pH unit	7.0				APHA 4500-H+ B
Conductivity	µS/cm	751				APHA 2510 B
Biochem Oxygen Demand (BOD5)	mg/L	<2				APHA 5210 B
Total Suspended Solids	mg/L	5				APHA 2540 D
Ammonia Nitrogen	mg/L	0.59				EL13F
Nitrate Nitrogen	mg/L	4.08				EL15F
Nitrite Nitrogen	mg/L	0.05				EL14F
Total Nitrogen	mg/L	4.99				EL30F
Orthophosphate	mg/L	0.03				EL10F
Total Phosphorus	mg/L	0.12				EL18F
Oil & Grease	mg/L	<2				EL23A
Thermotolerant Coliforms	cfu/100mL	0				ELM 3

Comments

Sample(s) collected by client and analysed as received in accordance with "Standard Methods for the Examination of Water & Wastewater", 24th Edition, 2023, APHA. Raw data sheets stating analysis dates are available upon request.

Tests marked with '#' are not covered by NATA Accreditation.

Measurement Uncertainty is available upon request.

Report Date: 28/10/25



Accredited for compliance with ISO/IEC 17025 - Testing
Accreditation Number: 12359

Approved:

Shane Ewart
Technical Supervisor
Microbiology and Chemistry

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian and International standards.