

## Analysis of Water Sample

**Client** Glen Innes Severn Council,  
 Glen Innes Sewage Treatment Works *Report* 24<sup>th</sup> July 2022  
*Water Sample collected* 19<sup>th</sup> July 2022 *Analysis complete* 24<sup>th</sup> July 2022  
*Sample collected by* Emily Leach  
 Samples received chilled - 19<sup>th</sup> July 2022

## RESULTS - Glen Innes 19<sup>th</sup> July 2022

mg L<sup>-1</sup> = part per million)

Parameter			Licence Limit (90th%ile)	Units	Method
Ammonia NH <sub>3</sub> -N	0.7		2	mg L <sup>-1</sup>	APHA 4500-NH <sub>3</sub> C
Biochemical Oxygen Demand (5 days)	4.0		10	mg L <sup>-1</sup>	APHA 5210 B
Elect. conductivity (EC)	559			uS cm <sup>-1</sup>	APHA 2510 B
Faecal Coliforms	1		200	cfu/ 100 mL	Membrane Filter APHA 9222 D
NO <sub>2</sub> and NO <sub>3</sub> -N	1.05			mg L <sup>-1</sup>	APHA 4110 B
Oil & Grease	<2		2	mg L <sup>-1</sup>	USEPA 1664
pH	7.40		6.5-8.5	pH units	APHA 4500-H <sup>+</sup> B
Soluble Reactive P (SRP)	0.084			mg L <sup>-1</sup>	APHA 4110 B
Total phosphorus	0.19		0.3	mg L <sup>-1</sup>	APHA 4500 P E
TKN - N	3.9			mg L <sup>-1</sup>	APHA 4500-N <sub>org</sub> C
TN	4.9		10	mg L <sup>-1</sup>	TKN + NO <sub>2</sub> +NO <sub>3</sub>
Total suspended solids TSS	8		15	mg L <sup>-1</sup>	APHA 2540 D

0<0.x = measured but reading below detection level

**Reference:** APHA (2005) *Standard Methods for the Examination of Water and Wastewater*. 21st Edition 2005.

**Comments.** Please note the Lower detection limit under USEPA 1664 is 2 mg/L for Oil & Grease

Glen Innes Weir - elemental analysis										
JULY 2022	Na	K	Mg	Ca	SAR	Hardness	Sulphur	TDS	Alkalinity	Chloride
Glen Innes- 19JUL22	mg/L	mg/L	mg/L	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L
	51.4	10.3	22.0	28.1	1.8	161	16.4	375	138	69



Commercial and research laboratory for soil, water and plant analysis.  
 Soil survey and analytical assessments, landscape analysis and plant nutrient relationships,  
 Wastewater and effluent reuse specialists - on-site and decentralised