Phone Office/Lab (02) 6775 1157

ABN: 72 212 385 096

email: <u>lanfaxlabs@bigpond.com.au</u>
Website: <u>http://www.lanfaxlabs.com.au</u>

Lab address: 493 Old Inverell Road Postal: PO Box 4690 Armidale NSW 2350

Director: Dr Robert Patterson CPSS,

Soil Scientists and Environmental Engineers



Quality Assurance and Quality Control by Approved Methods

Analysis of Water Sample

Client Glen Innes Severn Council,

Glen Innes Sewage Treatment Works Report 12th February 2024
Water Sample collected 6th February 2024 Analysis complete 12th February 2024
Sample collected by Emily Leach Samples received chilled 2nd January 2024

RESULTS - GLEN INNES - 6th February 2024

mg L-1 = part per million

Parameter		EPA Limit 90 th %ile	Units	Method
Ammonia NH ₃ -N	1.38	2.0	mg L ⁻¹	APHA 4500-NH ₃ C
Biochemical Oxygen Demand (5 days)	2.6	10	mg L ⁻¹	APHA 5210 B
Elect. conductivity (EC)	864		uS cm ⁻¹	APHA 2510 B
Faecal Coliforms	15	200	cfu/ 100 mL	Membrane Filter APHA 9222 D
NO ₂ and NO ₃ -N	2.08		mg L ⁻¹	APHA 4110 B
Oil & Grease	<2	2	mg L ⁻¹	USEPA 1664
рН	7.52	6.8-8.5	pH units	APHA 4500-H ⁺ B
Soluble Reactive P (SRP)	0.08		mg L ⁻¹	APHA 4110 B
Total phosphorus	0.30	0.3	mg L ⁻¹	APHA 4500 P E
TKN - N	2.6		mg L ⁻¹	APHA 4500-N _{org} C
TN	4.7	10	mg L ⁻¹	$TKN + NO_2 + NO_3$
Total suspended solids TSS	8	15	mg L ⁻¹	APHA 2540 D

0 < 0.x = measured but reading below detection level

Reference: APHA (2005) *Standard Meth230ods for the Examination of Water and Wastewater*. 21st Edition 2005. **Comments**. Please note the Lower detection limit under USEPA 1664 is 2 mg/L for Oil & Grease

Glen Innes Weir - elemental analysis											
FEBRUARY 2024	Na	K	Mg	Ca	SAR	Hardness	Sulphur	TDS	Alkalinity	Chloride	
Glen Innes	mg/L	mg/L	mg/L	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L	
06FEB24	84.8	20.0	29.1	30.1	2.6	195	31.5	579	118	187	

